

Pressure Vessel Survey										
Location:	Point Tupper	Ipper EM&I J Report No								
Client Name:		Client Ref No.:			PT-11564778-002-D2008					
Client Rep.:		Inspector Name:	Doug MacDo			onald				
WO No.:		Inspection Date:		May 21, 2009			9			
SPO No.:		System:		Propane + Liquids						
Workscope No.:	PT-2009-D2008-INT-01	EM&I J Job No:	EMJ0132.33							
Tag No.:	D-2008	Equipment Descrip				orage Vessel D-2008				
Date of Last Inspection:		Previous Records								
Drawing No.:										
	Drawing No.: LA-B22-F-22-8006-01-Z4, 98-CA-399735-4B Inspection Summary									
	Condition Comments									
External Ladders, Access a	and Support Structure		Good	Fair	Poor	NA	Internal Inspection Only			
1. If applicable, check lad	ders. stairways. platforms and	d walkwavs that are					Uniy			
1. If applicable, check ladders, stairways, platforms and walkways that are connected to, or bearing on the vessel for signs of corrosion, missing components, or deterioration.						\boxtimes				
If applicable, check vesse deflection, and/or corrosion.				\boxtimes						
3. If applicable, check coatin blistering, and/or coating dist	gs for signs of deterioration, rust	ts spots, cracks,				\boxtimes				
4. a) For horizontally mounted	d vessels, check for signs of trap n cradle support and vessel shel					\boxtimes				
 b) For vertically mounted v condensation, resulting in cor 				\boxtimes						
	support legs to the bottom cap.									
5. Check the grounding connection is correctly installed, with cable connections tight and ground wires in good condition.						\boxtimes				
	ns for any signs of corrosion or r	mechanical damage.				\boxtimes				
	ssel sliding foot free to move and	-								
Vessel External Surfaces			Good	Fair	Poor	NA				
	ing tags on vessel are legible an	d present the	\square				See Photo #1 and			
required information.	I bolts/stude extend fully through	their nuts having a					Note 1			
2. If applicable, check that all bolts/studs extend fully through their nuts, having a protrusion beyond the nut of not less than one thread; flange bolts have bolt heads all on the side of the joint.						\boxtimes				
3. If applicable, check bolted connections are in full contact with connected elements and connections for any signs of rust, corrosion or mechanical damage.						\boxtimes				
	ion support bands and clips for s					\square				
5. Check all welded seams and corrosion, cracking, pitting or				\boxtimes						
If applicable, check insulat				\boxtimes						
ingress of water. Record insu 7. Carry out visual inspectior										
coatings for any signs of leak other forms of deterioration.				\boxtimes						
8. If applicable, check weep holes in reinforcement plates are not plugged.						\square				
External Piping / Instrument Attachments					Poor	NA				
1. If applicable, check vessel trim, such as gauges, sight glasses, valves and										
other appurtenances, show signs of deterioration, or missing components, etc.						\boxtimes				
2. If applicable, check if the PSV on the vessel is in calibration. Record tag number of PSV and calibration date.						\boxtimes				
3. Inspect fittings, nozzles and other connections, including the surrounding vessel shell / head for any signs of distortion or cracks, wall loss, leakage, deterioration of coatings, etc. Specify extent and location.						\boxtimes				
Vessel Internal Surfaces	Good	Fair	Poor	NA						



Inspection Summary							
Item		Cond	dition	Comments			
1. Check for signs of corrosion, erosion, cracks, blisters, pitting, distortion, or other forms of deterioration on the internal vessel surfaces. If any, specify type, location and extent.					Overall vessel interior in good condition, exhibiting only minor surface corrosion (see Photo #2 and Note 2)		
 Check all welded joints for any signs of deterioration, corrosion, cracking, pitting or other sign of failure. Specify. 					All vessel weld seams deemed to be in good condition based on close visual inspection. MPI used to spot check every second circ weld and all accessible Tee joints (see attached MPI report and Photo #3&4)		
3. Check all man-ways, nozzles and connections for distortion, cracks, corrosion, wall loss and other type of defects or failures. If any defects are noted, specify type, extent and location.					All nozzles deemed to be in good condition based on close visual inspection (see Photo #5-16). Nozzle N6, N3B, N4B, N5, N1 also checked with MPI (see attached MPI report and Photo #12)		
 If applicable, compare the results of performed wall thickness survey with previous reports for areas of wall thickness loss. Identify areas on inspection report. 				\boxtimes	UT not conducted for internal inspection		
5. Where applicable, check vessel internal cladding for signs of bulging, buckling, cracks, holes, etc. If any, specify type, location and extent.				\boxtimes	No internal cladding in this vessel		
6. Where applicable, check the vessel internal coating for signs of deterioration, such as: rust spots, blisters, coating disbandment, etc. If any, specify type, location and extent.				\boxtimes	No internal coating in this vessel		
7. If possible, check gasket seals on all flanges for signs of corrosion and/or mechanical damage.				\boxtimes			
Internal Equipment/Piping /Supports	Good	Fair	Poor	NA			
 Where applicable, check supports for vessel's internal equipment and components for signs of corrosion, distortion and deterioration. 					Vortex breaker over N2 supported by four legs. The steel angle legs are intact and in good condition		
If applicable, check vessel's internals for signs of corrosion, distortion and deterioration, missing components etc.		\boxtimes			Top deck of vortex breaker dislodged and out of position at time of inspection (see Note 3)		
3. If applicable, check if bolted connections are in full contact with connected elements and connections are free from rust or other deleterious material that may prohibit full contact.	\boxtimes				No bolted connections (see Note 3)		



Detail of Findings

Instructions: With the aid of Drawing(s), Sketch(es) and Photo(s) describe findings

Note 1:

Certified By: RNG Pro-Tech Inc MAWP: 250/-11 PSI @149F // 1724/-76 KPa @ 65C MDMT: -17F @ 250/-11 PSI // -27C @ 1724/-76 KPa Serial No. : 98-11 Year Built: 1999 CRN: 8123.8 Diameter: 144" ID // 3.66 m Capacity: 104904 USWG // 397105 L Item No: D2008 Department of Labour Identification No.: 007984

Note 2:


Tank was thoroughly cleaned prior to internal inspection. Internal surfaces carefully checked with close visual inspection. Overall very good condition with internal surfaces exhibiting light surface corrosion and mill scale. Some residual debris remaining in tank bottom, however it did not hinder inspection. Particular attention given to tank bottom from the 5 through 7 o'clock positions. Only features noted were slight depressions attributed to discontinuities in the mill scale. No pitting or other discontinuities noted.

Note 3:


The Vortex breaker is located over top of 10 inch liquid outlet Nozzle N2. The structural frame of the vortex breaker comprises four vertically oriented support legs made from steel angle bracket. The structural box frame is completed with the addition of steel strapping around the perimeter of the frame. There are two levels of strapping. The lower level supports a lower grate whereas the upper grating supports the upper grate. The top grate was noted to be dislodged from its intended position when the vessel was initially entered. It was displaced from its position in the structural frame over top of the bottom grate and nozzle N2. It is difficult to ascertain when the grate was displaced. It could have been a result of the cleaning and washing process.

It was noted that the grates were fixed in position via a short tack weld to each of the support legs. The tack welds for the upper grating had failed allowing the grate to move out of its intended position. The tack weld did not appear to have structural load capacity. They may have used to keep the grates in position during shipping from fabrication site to Point Tupper. It is also noted that the manufacturer's drawing for this vessel (RNG Pro-Tech Dwg. No. 980047-1 sheet 2 of 2) states that the grating shall not be welded to the legs. For this reason, the displaced upper grating was simply placed back into its original position over the lower grating prior to the vessel being placed back in service. The pertinent features of the vortex breaker are shown and described in Photos #17-21.





















Detail of Findings

Instructions: With the aid of Drawing(s), Sketch(es) and Photo(s) describe findings





Detail of Findings

Instructions: With the aid of Drawing(s), Sketch(es) and Photo(s) describe findings



Photo 21 – Clear view of Northwest support leg. All components visible including upper and lower strapping, lower grating and lower grating tack weld

List of Attachments

Attachment 1: PT-D2008-090503-DL-MPI Attachment 2: PT-D2008-090521-NE-MPI

End of Report



MPI Survey							
Location:		Point Tupper		EM&I J Report No.:	PT-D2008-090503-DL-MPI		
Client Name:	ne: Exxon Mobil Sable Client Ref No.:		Client Ref No.:	PT-11564778-001-D2008			
Client Rep.: Dale Groves			Inspector Name:	Daniel Lewis			
WO No.: 1150		11564778		Inspection Date:	May 03, 2009		
SPO No.: 4501905471			Inspection Time:	Various			
Workscope No.: PT-2009-D20		008-INT-01	System:	Propane + Liquids			
Previous Report No. NA		NA		EM&I J Job No:	EMJ0132.43		
Ref. Drawing No.:		LA-B22-F-22-8006-01-Z4, 980047, 98-CA-399735-4B					
Technician Certifications:		PCN MPI LV	′L 2	Certification Expiry Date:	May 05, 2012		
Inspection Code:		ASME VIII		Inspection Procedure:	MT401ASME		
Material:		C/S		Surface Condition:	Needle gun		
Consumables:	Contrast:	White	Type: WCP-2	Manufacturer: Magnaflux	Batch: 07H14K/2755		
Equipment:	Type: Y5		S/N: 1450	Calibration Due: 40 Lb Cal lif	Current Type: N/A		

Inspection Summary

Comments:

MPI was conducted on the man-way hinges of vessel D-2008.

Restricted access to hinge welds. 50% of weld not able to be inspected due to geometry of hinge.

Foil strip Type 1 indicator (Brass finish) used to test sensitivity. Sensitivity achieved on areas of inspection.

No abnormalities were found in area of inspection.

Daniel Lewis PCN #302198

Ink Manufacturer: Magnaflux Type: 7HF Solution: Prepared bath Batch: 07G07K/3679

End of Report



MPI Survey							
Location:		Point Tupper		EM&I J Report No.:	PT-D2008-090521-NE-MPI		
Client Name:		Exxon Mobil Sable Client Ref No.:		Client Ref No.:	PT-11564778-002-D2008		
Client Rep.:	ent Rep.: Dale Groves		Inspector Name:	Neil English			
WO No.: 11564778			Inspection Date:	May 21, 2009			
SPO No.:	O No.: 4501905471		Inspection Time:	Various			
Workscope No.:	Workscope No.: PT-2009-D2008-INT-01		008-INT-01	System:	Propane + Liquids		
Previous Report No. NA			EM&I J Job No:	EMJ0132.43			
Ref. Drawing No.:		LA-B22-F-22-8006-01-Z4, 98-CA-399735-4B-0					
Technician Certifications:		CGSB MPI LVL 2		Certification Expiry Date:	December 31, 2011		
Inspection Code:		ASME VIII		Inspection Procedure:	MT401ASME		
Material:		C/S		Surface Condition:	Wire Brush cleaned		
Consumables:	Contrast:	White	Type: 8901w	Manufacturer: Ardrox	Batch: 65082407		
Equipment:	Equipment: Type: Y6		S/N: 12764	Calibration Due: 10 Lb Cal lif	ft Current Type: AC		

Inspection Summary

Comments:

Black on white Magnetic Particle Inspection was conducted on the Off-Spec Storage Vessel D-2008. Nozzles N6, N3B, N4B, N5 & N1 were inspected. Also, two foot spot checks on every second circular seam were inspected in the 3, 6, and 9 O'clock positions, as well as any accessible Tee joint.

At time of inspection no relevant indications were observed.

Foil strip Type 1 indicator (Brass finish) used to test sensitivity.

Neil English CGSB: #11752

Ink Manufacturer: Ardrox Type: 8031, Black Ink Solution: Prepared bath, Aerosol Batch:32111507