

	Droccur	e Vessel Survey							
Location:	Point Tupper	EM&I J Report N	٥.		PT-D2	100R-	·090320-BR-R1		
Client Name:	l onit rupper	Client Ref No.:	U. .				3-001-D2100B		
Client Rep.:		Inspector Name:							
WO No.:		Inspection Date:	,						
SPO No.:		System:	Propane						
Workscope No.:	PT-2008-VESSEL-EXT-03	EM&I J Job No:							
Tag No.:	D-2100B	Equipment Desc	cription: Propane Storage Vessel D-2						
	NA	Previous Record	ls See	n:	NA				
Drawing No.:	LA-B23-F-22-8050-01-Z5, 98	-CA-399735-1B-5,	98-CA	-3997	735-4B	-0			
	Inspec	tion Summary							
	Item	-		Con	dition		Comments		
External Ladders, Access a	and Support Structure		Good	Fair	Poor	NA			
	ders, stairways, platforms and he vessel for signs of corrosion, r								
2. If applicable, check vesse deflection, and/or corrosion.	I supports for signs of deterioratio	n, settlement,					See Photo #3		
	gs for signs of deterioration, rusts condment.	spots, cracks,							
4. a) For horizontally mounter resulting in corrosion between		\boxtimes				See Photo #3 & 6			
b) For vertically mounted v condensation, resulting in color or area of attachment of the s				\boxtimes					
5. Check the grounding connection is correctly installed, with cable connections tight and ground wires in good condition.							See Photos #7-10		
	ns for any signs of corrosion or m								
free.	ssel sliding foot free to move and	hold-down bolts are							
Vessel External Surfaces			Good	Fair	Poor	NA			
 Check permanent identify required information. 	ing tags on vessel are legible and	present the					See Photo #11-14		
	Il bolts/studs extend fully through to not less than one thread; flange b								
3. If applicable, check bolted elements and connections fo		\boxtimes							
4. If applicable, check insulat breakage.	ion support bands and clips for sig	gns of corrosion or							
5. Check all welded seams a corrosion, cracking, pitting or	nd connections for any signs of de other sign of failure. Specify.	eterioration,							
6) If applicable, check insulat ingress of water. Record insu	ion type, condition for any insulati Ilation type.	on damage and				\boxtimes			
coatings for any signs of leak	n of the exterior surface of the ves is, cracks, deformation, distortion, If so, specify type, location and ex	pitting, corrosion or	\boxtimes				See Photos #21-27		
	holes in reinforcement plates are	not plugged.							
External Piping / Instrumen			Good	Fair	Poor	NA			
other appurtenances, show s	I trim, such as gauges, sight glass igns of deterioration, or missing c	omponents, etc.							
number of PSV and calibration			\boxtimes				See Photo #34		
	d other connections, including the distortion or cracks, wall loss, leak and location.								



Inspection Summary									
Item		Cond	dition	Comments					
Vessel Internal Surfaces	Good	Fair	Poor	NA	External Only				
1. Check for signs of corrosion, erosion, cracks, blisters, pitting, distortion, or other forms of deterioration on the internal vessel surfaces. If any, specify type, location and extent.				\boxtimes					
2. Check all welded joints for any signs of deterioration, corrosion, cracking, pitting or other sign of failure. Specify.				\boxtimes					
3. Check all man-ways, nozzles and connections for distortion, cracks, corrosion, wall loss and other type of defects or failures. If any defects are noted, specify type, extent and location.				\boxtimes					
4. If applicable, compare the results of performed wall thickness survey with previous reports for areas of wall thickness loss. Identify areas on inspection report.				\boxtimes					
5. Where applicable, check vessel internal cladding for signs of bulging, buckling, cracks, holes, etc. If any, specify type, location and extent.									
6. Where applicable, check the vessel internal coating for signs of deterioration, such as: rust spots, blisters, coating disbandment, etc. If any, specify type, location and extent.				\boxtimes					
7. If possible, check gasket seals on all flanges for signs of corrosion and/or mechanical damage.				\boxtimes					
Internal Equipment/Piping /Supports	Good	Fair	Poor	NA					
1. Where applicable, check supports for vessel's internal equipment and components for signs of corrosion, distortion and deterioration.				\boxtimes					
2. If applicable, check vessel's internals for signs of corrosion, distortion and deterioration, missing components etc.				\boxtimes					
3. If applicable, check if bolted connections are in full contact with connected elements and connections are free from rust or other deleterious material that may prohibit full contact.				\boxtimes					
Detail of Findings Instructions: With the aid of Drawing(s), Sketch(es) and	Photo	(s) de	scribe	findin	ns.				

UT thickness readings were taken on areas where coating breakdown was noted. No areas of concern

ID Tag:

Certified By: Trenergy Inc MAWP: 1724/-62 KPAG @ 65C MDMT: -27C @ 1724/-62 KPAG

Serial No.: 063 Year Built: 1999 **CRN:** 9094.8

MAWP: 250/-9 PSIG @ 149F MDMT: -16.6F @ 250/-9 PSIG

Serial No.: 063 Year Built: 1999 CRN: 9094.8

PSV Tag:

L&S Job: 09-16828-17 Date: March 4, 2009 Set Pressure: 1723 KPA Capacity: 18649 SCFM Model: JPVM 15A

Detail of Findings





Photo 1 – Showing North face of North vessel support, paint coating in good condtion

Photo 2 – Showing South face of North vessel support, coating breakdown and corrosion only on lower flange connection to concrete





Photo 3 – Steel to concrete connection, coating breakdown mainly on edges

Photo 4 – South face of South vessel support, paint in good condtion

Detail of Findings





Photo 5 – North face of South vessel support, paint coating in good condtion. Coating breakdown on lower flange mainly

Photo 6 – Close-up of lower flange, no water damage or trapped moisture, paint coating flaking





Photo 7 – Earthing strap connection North vessel support

Photo 8 – Earthnig strap and connections on North vessel support

Detail of Findings





Photo 9 – Earthing strap connection on South vessel support

Photo 10 – Earthing strap on vessel support South side, general photo





Photo 11 – Showing ID plate

Photo 12 - Showing ID plate

Detail of Findings





Photo 13 - Showing ID plate

Photo 14 – Showing ID plate








Photo $16-Nzzles\ N3B\ \&\ N4B$, coating breakdown and light corrosion located on nozzle body and flange, studs and nuts CAT III

Detail of Findings





Photo 17 – Nozzle N2, coating breakdown only on flange connection. Studs and nuts uncoated but in good condtion, CAT III

Photo 18 – Nozzle N5, coating breakdown only located on flange connection. Studs and nuts CAT III $\,$





Photo 19 – Manhole, coating breakdown on flanges only, studs and nuts uncoated, CAT III

Photo 20 - N10, insulation bag in good condtion, studs and nut CAT III

Detail of Findings





Photo 21 – General condtion of East side shell, good condtion

Photo 22 – General condtion of East side shell, good condtion





Photo 23 – General condtion of East side shell, good condtion

Photo 24 – General good condtion of North dome end, photo taken facing South

Detail of Findings





Photo 25 – West side shell generally in good condtion

Photo 26 – West side shell generally in good condtion








Photo 28 – Showing 4 small isolated patches of coating breakdown and light corrosion on the upper South-East side shell Dome end

Detail of Findings





Photo 29 – Nozzles N3A/N4A/N8/N1, coating breakdown and light to moderate corrosion located only on flange edges. All studs and nuts are uncoated but in good condtion, CAT III

Photo 30 – South-West upper side shell, water staining only good condtion



Photo 31 – Nozzle N9, coating breakdown on flange connection, only studs and nuts have lost paint coating but are still in good condtion, CAT III



Photo 32 – Generally good condtion on top section of vessel, photo taken facing North

Detail of Findings





Photo 33 – Nozzle N7, coating breakdown only on flange connection, studs and nuts CAT II

Photo 34 - PSV calibration Tag





Photo 35 – East top side of North dome, good condtion

Photo 36 - Condtion of top West side of North dome

Detail of Findings





Photo 37 – General view of top section of vessel in good condtion

Photo 38 – Typical condtion of deluge pipe support



Photo 39 – General view of upper side shell West side, six very small areas of coating breakdown and light corrosion, photo taken facing South



List of Attachments

Attachment 1: PT-D2100B-090315-VR-UT (Page 1 to 2) Attachment 2: PT-D2100B-090511-JL-UT (Page 1 to 3)

Attachment 3: UT Diagram

End of Report



	U	Itrasoni	c Inspect	ion S	ur	vey for Vessel Ir	spect	ion		
Location:		Point Tup				EM&I J Report No		PT-D2100B-090315-VR-UT		
Client Name:		Exxon M	obil Sable			Client Ref No.:		PT-115736	13-001-D2100B	
Client Rep.:		Dale Gro	ves			Inspector Name:		Victor Ritch	nie	
WO No.:		1157361	11573613			Inspection Date:		March 15, 2	2009	
SPO No.:		4501869140				Inspection Time:		Various		
Workscope No.:		PT-2008-	PT-2008-VESSEL-EXT-03			System:		Propane		
Previous Report N	lo.	NA				EM&I J Job No:		EMJ0132.3	33	
Ref. Drawing No.:		LA-B23-F-22-8050-01-Z5, 9				CA-399735-1B-5, 98	-CA-399	9735-4B-0		
Technician Certifications: PCN UT 2					Certification Expir	y Date:	January 29, 2014			
Inspection Code:		NA				Inspection Proced	lure:	EM&I		
Item Inspected:		D2100B				Material (Incl. Vol.):	CS		
Surface Condition	1	As coate	d			Surface Temp:		Ambient		
Instrument	Туре	: Epoch L	TC	Equip	me	ent S/N: 090100701	Cal D	ue Date: Ja	anuary 24, 2010	
Instrument Setting	gs Refe	rence Lev	el: 80fsh	Gain:	50	db	Rejec	ct Settings: NA		
Search Unit Cable	s Type):		Lengt	h:	: 5' Transfer V			r Value:	
Calibration Block:		Step wed	lge 2.5-12.5	īmm	C	alibration Block S/N	N :	CB2		
Simulation Block:		NA			Couplant: Ultragel					
Computerized Pro	gram:	NA								
Transducer Mfg:	Type:		Model No).:		Angle: Free		ency:	Size:	
Panametrics	dual elen	ual element D790SM				0	5MHz		10mm	

Restricted Access?	Yes	☑ No	Comments:
Comments:			
UT measurments were taken This does not constitute a UT See below for locations and re	survey.		

Inspection Summary



Inspection Summary

Item Identification	Test Point	Diameter (inches)	Nominal Wall Thickness (mm)	Minimum Wall Thickness (mm)	Average Wall Thickness (mm)
Shell Bottom	TP1	144"	28.6	29.7	N/A
Shell Bottom	TP2	144"	28.6	29.4	N/A
Shell Bottom	TP3	144"	28.6	29.8	N/A
Shell Bottom	TP4	144"	28.6	30.3	N/A
Shell Bottom	TP5	144"	28.6	30.5	N/A
Shell Bottom	TP6	144"	28.6	30.4	N/A
Shell Bottom	TP7	144"	28.6	30.2	N/A
Shell Bottom	TP8	144"	28.6	30.4	N/A
Shell Bottom	TP9	144"	28.6	30.1	N/A
Shell Bottom	TP10	144"	28.6	30.0	N/A
Shell Bottom	TP11	144"	28.6	29.2	N/A
Shell Bottom	TP12	144"	28.6	29.4	N/A
Shell Bottom	TP13	144"	28.6	29.6	N/A
Shell Bottom	TP14	144"	28.6	29.6	N/A
Shell Bottom	TP15	144"	28.6	29.4	N/A
Shell Bottom	TP16	144"	28.6	29.0	N/A
Shell Bottom	TP17	144"	28.6	29.3	N/A
Shell Bottom	TP18	144"	28.6	29.3	N/A
Shell Bottom	TP19	144"	28.6	30.8	N/A
Shell Bottom	TP20	144"	28.6	30.6	N/A
Shell Bottom	TP21	144"	28.6	30.8	N/A
Shell Bottom	TP22	144"	28.6	29.8	N/A
Shell Bottom	TP23	144"	28.6	29.6	N/A
Shell Bottom	TP24	144"	28.6	30.0	N/A
Shell Bottom	TP25	144"	28.6	30.1	N/A
Shell Bottom	TP26	144"	28.6	29.8	N/A
Shell Bottom	TP27	144"	28.6	30.4	N/A
Shell Bottom	TP28	144"	28.6	30.4	N/A
Shell Bottom	TP28	144"	28.6	31.0	N/A
Shell Bottom	TP29	144"	28.6	30.8	N/A
Shell Bottom	TP30	144"	28.6	30.4	N/A
Shell Bottom	TP32	144"	28.6	30.6	N/A
Shell Bottom	TP33	144"	28.6	30.4	N/A
Shell Bottom	TP34	144"	28.6	30.4	N/A
Shell Bottom	TP35	144"	28.6	30.6	N/A
Shell Bottom	TP36	144"	28.6	30.4	N/A

End of Report



	U	Itrasoı	nic Inspect	ion S	ur	vey for Vessel In	spectio	n		
Location:		Point T	upper		EM&I J Report No.:			PT-D2100B-090511-JL-UT		
Client Name:		Exxon	Mobil Sable			Client Ref No.:		PT-1157	'3613-001-D2100B	
Client Rep.:		Dale G	roves			Inspector Name:		John Lee	е	
WO No.:		115736	11573613			Inspection Date:		March 1	1, 2009	
SPO No.:		450186	4501869140			Inspection Time:		Various		
Workscope No.:		PT-2008-VESSEL-EXT-03				System:		Propane	,	
Previous Report N	lo.	NA				EM&I J Job No:		EMJ013	2.33	
Ref. Drawing No.:		LA-B23	3-F-22-8050-0)1-Z5, 9	98-0	CA-399735-1B-5, 98-	CA-3997	35-4B-0		
Technician Certific	Technician Certifications: PCN UT 2					Certification Expir	y Date:	May 21, 2012		
Inspection Code:	pection Code: NA					Inspection Proced	ure:	EM&I		
Item Inspected:		D2100	В			Material (Incl. Vol.)):	C/S		
Surface Condition	:	As coa	ted			Surface Temp:		Ambient		
Instrument	Туре	: Epoch	LTC	Equip	me	ent S/N: 090108103	Cal Due	e Date: March 11, 2010		
Instrument Setting	gs Refe	rence L	evel: 80fsh	Gain:	60	db	Reject	Settings: NA		
Search Unit Cable	s Type	:		Lengt	h:	5'	Transfe	er Value:		
Calibration Block:			edge 2.5-12.5	5mm	C	alibration Block S/N	<u> : </u>	09-1652		
Simulation Block:		NA			Couplant:			Ultragel II		
Computerized Pro	gram:	NA								
Transducer Mfg:	Type:		Model No.:				Frequen	cy:	Size:	
Panametrics	dual elen	nent	D790SM - 6	25220		0 5MHz			10mm	

Inspection Summary						
Restricted Access?	Yes Yes	∑ No	Comments: Rope Access Required			

Comments:

UT spot readings were taken and the readings were recorded. See below and Attachment 3 for locations and readings. All readings are in millimeters.

Readings on North cap were taken facing South and readings on South cap were taken facing North.



Inspection Summary

Item Identification	Test Point	Diameter (inches)	Nominal Wall Thickness (mm)	Minimum Wall Thickness (mm)	Average Wall Thickness (mm)	
North Head	rth Head 12 o'clock End		28.2	31.4	,,	
North Head	3 o'clock	End	28.2	31.3		
North Head	6 o'clock	End	28.2	30.6		
North Head	9 o'clock	End	28.2	30.6		
North Head	Centre	End	28.2	31.0		
South Head	12 o'clock	End	28.2	31.4		
South Head	3 o'clock	End	28.2	31.7		
South Head	6 o'clock	End	28.2	30.4		
South Head	9 o'clock	End	28.2	31.4		
South Head	Centre	End	28.2	31.2		
Panel 1	West	144"	28.6	29.5		
Panel 1	Centre	144"	28.6	29.6		
Panel 1	East	144"	28.6	29.8		
Panel 2	West	144"	28.6	29.9		
Panel 2	Centre	144"	28.6	29.7		
Panel 2	East	144"	28.6	28.9		
Panel 3	West	144"	28.6	29.7		
Panel 3	Centre	144"	28.6	29.7		
Panel 3	East	144"	28.6	30.1		
Panel 4	West	144"	28.6	28.7		
Panel 4	Centre	144"	28.6	29.3		
Panel 4	East	144"	28.6	28.8		
Panel 5	West	144"	28.6	29.6		
Panel 5	Centre	144"	28.6	29.5		
Panel 5	East	144"	28.6	29.4		
Panel 6	West	144"	28.6	29.8		
Panel 6	Centre	144"	28.6	30.4		
Panel 6	East	144"	28.6	30.5		
Panel 7	West	144"	28.6	30.6		
Panel 7	Centre	144"	28.6	30.3		
Panel 7	East	144"	28.6	30.1		
Panel 8	West	144"	28.6	29.6		
Panel 8	Centre	144"	28.6	30.1		
Panel 8	East	144"	28.6	29.8		



Inspection Summary

Item Identification	Test Point	Diameter (inches)	Nominal Wall Thickness (mm)	Minimum Wall Thickness (mm)	Average Wall Thickness (mm)
Panel 9	West	144"	28.6	29.6	
Panel 9	Centre	144"	28.6	29.5	
Panel 9	East	144"	28.6	29.8	
Panel 10	West	144"	28.6	29.3	
Panel 10	Centre	144"	28.6	30.0	
Panel 10	East	144"	28.6	29.5	
Panel 11	West	144"	28.6	30.7	
Panel 11	Centre	144"	28.6	30.0	
Panel 11	East	144"	28.6	29.5	
Panel 12	West	144"	28.6	30.4	
Panel 12	Centre	144"	28.6	30.3	
Panel 12	East	144"	28.6	30.3	

End of Report

Three UT readings were taken on each plate. One on the East, one top Center, and one on the West side. The areas are numbered and readings were recorded on the UT report. Only the lowest readings were reported.

