

Pressure Vessel Survey						
Location:	Point Tupper	EM&I J Report No.:	PT-D2100B-090506-CR-R0			
Client Name:		Client Ref No.:	PT-11564781-002-D2100B			
Client Rep.:		Inspector Name:	Colin Robinson			
WO No.:		Inspection Date:	May 06, 2009			
SPO No.:		System:	Propane			
Workscope No.:	PT-2009-D-2100B-INT-01	EM&I J Job No:	EMJ0132.43			
Tag No.:	D-2100B	Equipment Description:	Propane Storage Vessel D-2100B			
Date of Last Inspection:	NA	Previous Records Seen:	NA			
Drawing No.:	LA-B23-F-22-8050-01-Z5, 98	3-CA-399735-1B-5				

Inspection Summary							
Item Condition Comments							
External Ladders, Access and Support Structure		Internal Inspection Only; See Note 1					
1. If applicable, check ladders, stairways, platforms and walkways that are connected to, or bearing on the vessel for signs of corrosion, missing components, or deterioration.	NA						
If applicable, check vessel supports for signs of deterioration, settlement, deflection, and/or corrosion.	NA						
3. If applicable, check coatings for signs of deterioration, rusts spots, cracks, blistering, and/or coating disbondment.	NA						
4. a) For horizontally mounted vessels, check for signs of trapped moisture, resulting in corrosion between cradle support and vessel shell.	NA						
b) For vertically mounted vessels on skirt support or support legs, check for condensation, resulting in corrosion on the bottom cap/ inside skirt support surface or area of attachment of the support legs to the bottom cap.	NA						
5. Check the grounding connection is correctly installed, with cable connections tight and ground wires in good condition.	NA						
6. Check all bolted connections for any signs of corrosion or mechanical damage.	NA						
7. If applicable, check the vessel sliding foot free to move and hold-down bolts are free.	NA						
Vessel External Surfaces		Internal Inspection Only; See Note 1					
Check permanent identifying tags on vessel are legible and present the required information.	NA						
2. If applicable, check that all bolts/studs extend fully through their nuts, having a protrusion beyond the nut of not less than one thread; flange bolts have bolt heads all on the side of the joint.	NA						
3. If applicable, check bolted connections are in full contact with connected elements and connections for any signs of rust, corrosion or mechanical damage.	NA						
4. If applicable, check insulation support bands and clips for signs of corrosion or breakage.	NA						
5. Check all welded seams and connections for any signs of deterioration, corrosion, cracking, pitting or other sign of failure. Specify.	NA						
6) If applicable, check insulation type, condition for any insulation damage and ingress of water. Record insulation type.	NA						
7. Carry out visual inspection of the exterior surface of the vessel, including coatings for any signs of leaks, cracks, deformation, distortion, pitting, corrosion or other forms of deterioration. If so, specify type, location and extent.	NA						
8. If applicable, check weep holes in reinforcement plates are not plugged.	NA						
External Piping / Instrument Attachments	Internal Inspection Only; See Note 1						
1. If applicable, check vessel trim, such as gauges, sight glasses, valves and other appurtenances, show signs of deterioration, or missing components, etc.	NA						
2. If applicable, check if the PSV on the vessel is in calibration. Record tag number of PSV and calibration date.	NA						
3. Inspect fittings, nozzles and other connections, including the surrounding vessel shell / head for any signs of distortion or cracks, wall loss, leakage, deterioration of coatings, etc. Specify extent and location.	NA						



Inspection Summary					
ltem	Comments				
Vessel Internal Surfaces		See Note 2			
1. Check for signs of corrosion, erosion, cracks, blisters, pitting, distortion, or other forms of deterioration on the internal vessel surfaces. If any, specify type, location and extent.	Good	See Note 3			
2. Check all welded joints for any signs of deterioration, corrosion, cracking, pitting or other sign of failure. Specify.	Good	MPI carried out on selected T- junctions and weld seams (see Note 6)			
3. Check all man-ways, nozzles and connections for distortion, cracks, corrosion, wall loss and other type of defects or failures. If any defects are noted, specify type, extent and location.	Good	All nozzles in good condition (see Photo 4-10). MPI carried out on N3B, N4B, N5, N6, N10 and Manway M			
4. If applicable, compare the results of performed wall thickness survey with previous reports for areas of wall thickness loss. Identify areas on inspection report.	NA	Refer to external inspection report PT-11573613-001-D2100B for details			
5. Where applicable, check vessel internal cladding for signs of bulging, buckling, cracks, holes, etc. If any, specify type, location and extent.	NA	No internal cladding			
6. Where applicable, check the vessel internal coating for signs of deterioration, such as: rust spots, blisters, coating disbandment, etc. If any, specify type, location and extent.	NA	Not coated			
7. If possible, check gasket seals on all flanges for signs of corrosion and/or mechanical damage.	NA	All flanges isolated; spade in place			
Internal Equipment/Piping /Supports					
Where applicable, check supports for vessel's internal equipment and components for signs of corrosion, distortion and deterioration.	NA				
2. If applicable, check vessel's internals for signs of corrosion, distortion and deterioration, missing components etc.	Good	Vortex Breaker (see Note 6)			
3. If applicable, check if bolted connections are in full contact with connected elements and connections are free from rust or other deleterious material that may prohibit full contact.	NA	Welded internal Vortex Breaker (see Photo #10 & 11)			

Detail of Findings

Instructions: With the aid of Drawing(s), Sketch(es) and Photo(s) describe findings

Technical Characteristic of D-2100B:

- Commissioned in 1999
- Material: SA 516 70 (Carbon Steel)
- Operating Pressure and Temperature: 1380 KPag and 42°C.
- Design Pressure and Temperature: 1724 KPag and 65°C
- Corrosion Circuit: Propane Plus Liquids (LCC-02)
- Net Failure Consequence Rating: 14.8
- Internal Coating: None
- Corrosion Allowance: 1.6 mm

Note 1: A thorough external inspection of Propane Storage Vessel D-2100B was carried out under WO# 11573613 in accordance with API 510 and API 572; please refer to EM&I Jacques Report PT-11573613-001-D2100B for details.

Note 2: A thorough internal inspection of D-2100B was carried out in accordance with API 510 and API 572 by entering the vessel. The Vessel was found generally to be in good conditon. Light surface scaling and roughness on the vessel shell and head was noted. Residue was removed from the vessel during vessel cleaning process and sent for analysis, see Photo #16 & 17.

Note 3: Isolated areas of pitting were noted; approx. 1% - 2% by density located between 5 and 7 O'clock position; maximum depth 1mm with an aveage depth 0.5mm; please see Photo #3 and the attached drawing for locations.



Detail of Findings

Instructions: With the aid of Drawing(s), Sketch(es) and Photo(s) describe findings

Note 4: Name Plate Details:

• Certified By: Patterson Industries (Canada) Ltd

• The maximum allowable working pressure (MAWP): 250 & -9 PSI @ 149°F (1724 & -62Kpa @65 °C)

The minimum design metal temperature (MDMT): -16.6°F @ 250 & -9 PSI (-27°C @1724 & -62Kpa)

Serial No.: 063Year Built: 1998C.R.N.: 9094.8

Note 5: PSVD2100B details:

Certified By: Land & Sea Instrumentation Ltd. Job No. 09-16828-17

Date: March 4th, 2009
Set Pressure: 1723Kpa
Capacity: 18649 SCFM
Model: JPVM – 15A

Note 6: MPI was carried out on the Vortex Breaker on N2 to vessel shell weld; no indication was noted. Slight undercut was noted on the vortex breaker to vessel shell weld; MPI was carried out to confirm the integrity of the weld – No cracking noted.

Detail of Findings





Photo 1 - Name Plate Details

Photo 2 - Name Plate Details





Photo 3 - Close view of internal pitting

Photo 4 – General View of Nozzle N5 in good condition

Detail of Findings





Photo 5 – General View of Nozzle N10 in good condition

Photo 6 – General View of Nozzle N4B in good condition





Photo 7 – General View of Nozzle N3B in good condition

Photo 8 – General View of Nozzle N6 in good conditon



Detail of Findings





Photo 9 - Thermowell on Nozzle N6

Photo 10 – General View of Nozzle N2 with Vortex Breaker in good condition








Photo 12 - Grinding Marks on shell

Detail of Findings





Photo 13 - Typical 'T' Weld

Photo 14 - General View of North Head








Photo 16 - Residue removed from D-2100B



Detail of Findings

Instructions: With the aid of Drawing(s), Sketch(es) and Photo(s) describe findings





Photo 17 - Residue removed from D-2100B

Photo 18 - PSV Details

List of Attachments

Attachment 1: PT-D2100B-090503-DL-MPI Attachment 2: PT-D2100B-090505-NE-MPI

Attachment 3: 98-CA-399735-1B-5

End of Report



MPI Survey							
Location: Point Tup		Point Tupper	r	EM&I J Report No.:		PT-D2100B-090503-DL-MPI	
Client Name: Exxon Mobil		Sable Client Ref No.:		PT	PT-11564781-001-D2100B		
Client Rep.:		Dale Groves		Inspector Name:	Daniel Lewis		
WO No.:		11564781		Inspection Date:	May 03, 2009		
SPO No.:		4501905471		Inspection Time:	Various		
Workscope No.:		PT-2009-D2100B-INT-01		System:	Propane		
Previous Report	eport No. NA			EM&I J Job No:	EMJ0132.43		
Ref. Drawing No.: LA		LA-B23-F-22-8050-01-Z5, 98-CA-399735-1B-5					
Technician Certifications: PCN		PCN MPI LV	′L 2	Certification Expiry Date:		May 05, 2012	
Inspection Code: ASME		ASME VIII		Inspection Procedure:		MT401ASME	
Material:		C/S		Surface Condition:		Needle gun	
Consumables:	sumables: Contrast: White		Type: WCP-2	Manufacturer: Magnaflux		Batch: 07H14K/2755	
Equipment: Type: Y5		S/N: 1450	Calibration Due: 40 Lb Cal	lift	Current Type: NA		

Inspection Summary

Comments:

MPI was conducted on the man-way hinges of vessel D-2100B.

Restricted access to hinge welds. 50% of weld not able to be inspected due to geometry of hinge.

Foil strip Type 1 indicator (Brass finish) used to test sensitivity. Sensitivity achieved on areas of inspection.

No abnormalities were found in area of inspection.

Daniel Lewis PCN #302198

<u>Ink</u>

Manufacturer: Magnaflux

Type: 7HF

Solution: Prepared bath Batch: 07G07K/3679

End of Report



MPI Survey							
Location: Point Tupper		r EM&I J Report No.:		PT-D2100B-090505-NE-MPI			
Client Name:		Exxon Mobil Sable		Client Ref No.:	: PT-1156478		
Client Rep.:		Dale Groves		Inspector Name:	Neil English		
WO No.:		11564781		Inspection Date:	May 05, 2009		
SPO No.:		4501905471		Inspection Time:	Various		
Workscope No.:	scope No.: PT-2009-D2100B-IN		100B-INT-01	System:	Propane		
Previous Report	Previous Report No. NA			EM&I J Job No:	EMJ0132.43		
Ref. Drawing No.: LA-		LA-B23-F-22	LA-B23-F-22-8050-01-Z5, 98-CA-399735-1B-5				
Technician Certifications: CG		CGSB MPI LVL 2		Certification Expiry Date:		December 31, 2011	
Inspection Code: ASM		ASME VIII		Inspection Procedure:		MT401ASME	
Material:		C/S		Surface Condition:		Wire Brush cleaned	
Consumables:	onsumables: Contrast: White		Type: WCP-2	Manufacturer: Magnaflux		Batch: 07h14k	
Equipment: Type: Y6		S/N: 12764	Calibration Due: 10 Lb Cal lift		Current Type: AC		

Inspection Summary

Comments:

Black on white Magnetic Particle Inspection was conducted on the Propane Storage Vessel D-2100B. Nozzles N6, N3B, N4B, N5 & N1 were inspected. Also, two foot spot checks on every second circular seam were inspected in the 3, 6, and 9 O'clock positions, as well as any accessible Tee joint.

At time of inspection no relevant indications were observed.

Foil strip Type 1 indicator (Brass finish) was used to test sensitivity.

Neil English CGSB: #11752

<u>Ink</u>

Manufacturer: Magnaflux Type: 7HF Black Ink

Solution: Prepared bath, Aerosol

Batch:07G07K

