

Pressure Vessel Survey											
Location:	Point Tupper	EM&I J Report N	0.:		PT-D2100C-090319-BR-R1						
Client Name:		Client Ref No.:			PT-11573614-001-D2100C						
Client Rep.:		Inspector Name:		Barry Ritchie							
WO No.:		Inspection Date:			March	19, 20	009				
SPO No.:		System:			Propar						
Workscope No.:	PT-2008-VESSEL-EXT-03	EM&I J Job No:			EMJ01						
Tag No.:	D-2100C	<b>Equipment Desc</b>				ne Sto	rage Vessel D-2100C				
Date of Last Inspection:		Previous Record			NA						
Drawing No.:	LA-B23-F-22-8051-01-Z3, 98	-CA-399735-1B-5,	98-CA	-3997	35-4B	-0					
	Inspec	tion Summary									
	Item Condition Comments										
External Ladders, Access a	and Support Structure		Good	Fair	Poor	NA					
	lders, stairways, platforms and										
connected to, or bearing on t				Ш							
or deterioration.	el supports for signs of deterioration	n cottlement	_		<b>-</b>		See Photo #3				
deflection, and/or corrosion.	supports for signs of deterioration	n, semement,	$\boxtimes$				See F11010 #3				
	ngs for signs of deterioration, rusts	spots, cracks,				П					
blistering, and/or coating disk	oondment.	•		Ш		Ш					
	d vessels, check for signs of trapp	ed moisture,				П	Crack on South support				
	n cradle support and vessel shell.	lana abaak fan					See Photo #3 & 6				
	rosion on the bottom cap/ inside s					$\boxtimes$					
	support legs to the bottom cap.	skiit dappoit dariado									
	ection is correctly installed, with c	able connections					See Photos #7-10				
tight and ground wires in goo						Ш					
6. Check all bolted connection	ons for any signs of corrosion or mo	echanical damage.	$\boxtimes$								
7. If applicable, check the ve-	ssel sliding foot free to move and l	hold-down bolts are				$\boxtimes$					
free.					Ш						
Vessel External Surfaces			Good	Fair	Poor	NA	0 0 1 1 1/44 44				
1. Check permanent identifying tags on vessel are legible and present the required information.							See Photo #11-14				
2. If applicable, check that a					_						
protrusion beyond the nut of all on the side of the joint.				Ш							
	connections are in full contact with rany signs of rust, corrosion or me										
	tion support bands and clips for sig					$\boxtimes$					
breakage	1										

shell / head for any signs of distortion or cracks, wall loss, leakage, deterioration of coatings, etc. Specify extent and location.

 $\boxtimes$ 

 $\boxtimes$ 

Good

 $\boxtimes$ 

 $\boxtimes$ 

Fair

Poor

 $\boxtimes$ 

 $\boxtimes$ 

NA

5. Check all welded seams and connections for any signs of deterioration,

6) If applicable, check insulation type, condition for any insulation damage and

coatings for any signs of leaks, cracks, deformation, distortion, pitting, corrosion or

7. Carry out visual inspection of the exterior surface of the vessel, including

1. If applicable, check vessel trim, such as gauges, sight glasses, valves and

other appurtenances, show signs of deterioration, or missing components, etc.

2. If applicable, check if the PSV on the vessel is in calibration. Record tag

3. Inspect fittings, nozzles and other connections, including the surrounding vessel

other forms of deterioration. If so, specify type, location and extent.

8. If applicable, check weep holes in reinforcement plates are not plugged.

corrosion, cracking, pitting or other sign of failure. Specify.

ingress of water. Record insulation type.

**External Piping / Instrument Attachments** 

number of PSV and calibration date.

Flange connections only

See Photos #21-27

See Photo #35



Inspection Summary								
Item		Conc	lition	Comments				
Vessel Internal Surfaces	Good	Fair	Poor	NA	External Only			
1. Check for signs of corrosion, erosion, cracks, blisters, pitting, distortion, or other forms of deterioration on the internal vessel surfaces. If any, specify type, location and extent.				$\boxtimes$				
2. Check all welded joints for any signs of deterioration, corrosion, cracking, pitting or other sign of failure. Specify.				$\boxtimes$				
3. Check all man-ways, nozzles and connections for distortion, cracks, corrosion, wall loss and other type of defects or failures. If any defects are noted, specify type, extent and location.								
4. If applicable, compare the results of performed wall thickness survey with previous reports for areas of wall thickness loss. Identify areas on inspection report.				$\boxtimes$				
5. Where applicable, check vessel internal cladding for signs of bulging, buckling, cracks, holes, etc. If any, specify type, location and extent.				$\boxtimes$				
6. Where applicable, check the vessel internal coating for signs of deterioration, such as: rust spots, blisters, coating disbandment, etc. If any, specify type, location and extent.				$\boxtimes$				
7. If possible, check gasket seals on all flanges for signs of corrosion and/or mechanical damage.								
Internal Equipment/Piping /Supports	Good	Fair	Poor	NA				
1. Where applicable, check supports for vessel's internal equipment and components for signs of corrosion, distortion and deterioration.								
2. If applicable, check vessel's internals for signs of corrosion, distortion and deterioration, missing components etc.				$\boxtimes$				
3. If applicable, check if bolted connections are in full contact with connected elements and connections are free from rust or other deleterious material that may prohibit full contact.				$\boxtimes$				
Detail of Findings								

Instructions: With the aid of Drawing(s), Sketch(es) and Photo(s) describe findings

UT thickness readings were taken on areas where coating breakdown was noted. No areas of concern

ID Tag:

Certified By: Trenergy Inc MAWP: 210/-9 PSIG @ 149F MDMT: -16.6F @ 250/-9 PSIG

**Serial No.**: 062 **Year Built**: 1998 **CRN:** 9094.8

**MAWP:** 1724/-62 KPAG @ 65C **MDMT:** -27C @ 1724/-62 KPAG

**Serial No.**: 062 **Year Built**: 1998 **CRN**: 9094.8

**PSV Tag:** 

L&S Job: 09-16828-3 Date: February 24, 2009 Set Pressure: 1723 KPA Capacity: 18649 SCFM Model: JPV 15A

#### **Detail of Findings**





Photo 1 – North face of North vessel support, paint coating in good condtion

Photo 2 – South face of North vessel support, coating breakdown and corrosion only on lower flange connection to concrete





Photo 3 – Steel to concrete connection, coating breakdown mainly on edges

Photo 4 – South face of South vessel support, paint in good condtion

### **Detail of Findings**





Photo 5 – North face of South vessel support, paint coating in good condtion. Coating breakdown on lower flange mainly

Photo 6 – Close-up of lower flange and horizontal crack along top edge of concrete





Photo 7 – Earthing strap connection North vessel support

Photo 8 – Earthnig strap and connections on North vessel support



### **Detail of Findings**





Photo 9 – Earthing strap connection on South vessel support

Photo 10 – Earthing strap on vessel support South side, general photo





Photo 11 – Showing ID plate

Photo 12 - Showing ID plate

### **Detail of Findings**





Photo 13 - Showing ID plate

Photo 14 – Showing ID plate








Photo 16 – Nozzles N3B & N4B, coating breakdown and light corrosion located only on flange connection, studs and nuts CAT III

### **Detail of Findings**





Photo 17 – Nozzle N2, coating breakdown only on flange connection. Studs and nuts uncoated but in good condtion, CAT III

Photo 18 – Nozzle N5, coating breakdown only located on flange connection, studs and nuts CAT III





Photo 19 – Manhole, coating breakdown on flanges only. Studs and nuts uncoated, CAT III

Photo 20 - N10, insulation bag in good condtion, studs and nuts CAT III

#### **Detail of Findings**





Photo 21 – General condtion of East side shell, only a few small isolated patches of coating breakdown and light corrosion located on the upper section of shell

Photo 22 – General condtion of East side shell, only a few small isolated patches of coating breakdown and light corrosion located on the upper section of shell





Photo 23 – General condtion of East side shell, only a few small isolated patches of coating breakdown and light corrosion located on the upper section of shell

Photo 24 – General good condtion of North dome end, photo taken facing South

### **Detail of Findings**





Photo 25 – West side shell in general condtion, photo taken facing South

Photo 26 – West side shell in general condtion, photo taken facing South



Photo 27 – West side shell in general condtion. Showing small isolated patches of coating breakdown and light corrosion, larges patch measuring approx 50mm x 20mm all photos taken facing South



Photo 28 – Small isolated patches of coating breakdown and light corrosion on the upper South-East side shell Dome end

#### **Detail of Findings**





Photo 29 – Nozzles N3A/N4A/N8/N1, coating breakdown and light to moderate corrosion located only on flanges. All studs and nuts are uncoated but are in good condtion, CAT III

Photo 30 – South-West upper side shell, same as photo 27








Photo 32 – General good condtion of top section of vessel

### **Detail of Findings**





Photo 33 – Typical condtion of deluge pipe support

Photo 34 – Nozzle N7, coating breakdown only on flange connection. Studs and nuts CAT II






Photo 35 - PSV calibration Tag

Photo 36 – Coating breakdown and light corrosion on top of North dome, East side

#### **Detail of Findings**





Photo 37 – Coating breakdown and light corrosion on top of North dome, East side

Photo 38 – Very small isolated patches of coating breakdown on North dome, top Centre



Photo 39 – General view along top section of vessel, all good condtion, photo taken facing South



#### **List of Attachments**

Attachment 1: PT-D2100C-090315-VR-UT (Page 1 to 2) Attachment 2: PT-D2100C-090511-JL-UT (Page 1 to 3)

Attachment 3: UT Diagram

End of Report



Ultrasonic Inspection Survey for Vessel Inspection										
Location:		Point Tup	per			EM&I J Report No.	.:	PT-D2100C-090315-VR-UT		
Client Name:		Exxon M	obil Sable			Client Ref No.:		PT-11573	614-001-D2100C	
Client Rep.:		Dale Gro	ves			Inspector Name:	,	Victor Ritc	hie	
WO No.:		1157361	4			Inspection Date:		March 15,	2009	
SPO No.:		4501869	140			Inspection Time:	,	Various		
Workscope No.:		PT-2008-	-VESSEL-E	XT-03		System:		Propane		
Previous Report N	lo.	NA				EM&I J Job No:		EMJ0132.	33	
Ref. Drawing No.:		LA-B23-F	-22-8051-0	)1-Z3, 9	98-0	CA-399735-1B-5, 98-	-CA-3997	35-4B-0		
Technician Certific	cations:	PCN UT 2			Certification Expir	y Date:	January 29, 2014			
Inspection Code:		NA				Inspection Proced	lure:	EM&I		
Item Inspected:		D2100C				Material (Incl. Vol.)	):	CS		
Surface Condition	:	As coated				Surface Temp:		Ambient		
Instrument	Туре	: Epoch L	Epoch LTC Equipme			ent S/N: 090100701	Cal Du	<b>e Date:</b> Ja	nuary 24, 2010	
Instrument Setting	gs Refe	ence Level: 80fsh   Gain: 50			50	db	Reject	ct Settings: NA		
Search Unit Cable	s Type	):	Length:			5'	Transfe	sfer Value:		
Calibration Block:		Step wed	lge 2.5-12.5	5mm	Ü	alibration Block S/N	<b>l</b> :	CB2		
Simulation Block:		NA			Č	ouplant:		Ultragel		
Computerized Pro	gram:	NA								
Transducer Mfg:	Transducer Mfg: Type: Model No.:		).:		Angle: Frequen		су:	Size:		
Panametrics	dual elen	ment D790SM			0	5MHz		10mm		

Restricted Access?	Yes	☑ No	Comments:
Comments:			
UT measurments were taken This does not constitute a UT See below for locations and re	survey.	-	

**Inspection Summary** 



# **Inspection Summary**

Item Identification	Test Point	Diameter (inches)	Nominal Wall Thickness (mm)	Minimum Wall Thickness (mm)	Average Wall Thickness (mm)
Shell Bottom	TP1	144"	28.6	30.5	N/A
Shell Bottom	TP2	144"	28.6	30.7	N/A
Shell Bottom	TP3	144"	28.6	30.6	N/A
Shell Bottom	TP4	144"	28.6	30.9	N/A
Shell Bottom	TP5	144"	28.6	30.8	N/A
Shell Bottom	TP6	144"	28.6	30.9	N/A
Shell Bottom	TP7	144"	28.6	30.7	N/A
Shell Bottom	TP8	144"	28.6	30.3	N/A
Shell Bottom	TP9	144"	28.6	30.6	N/A
Shell Bottom	TP10	144"	28.6	30.8	N/A
Shell Bottom	TP11	144"	28.6	31.0	N/A
Shell Bottom	TP12	144"	28.6	30.9	N/A
Shell Bottom	TP13	144"	28.6	30.7	N/A
Shell Bottom	TP14	144"	28.6	31.1	N/A
Shell Bottom	TP15	144"	28.6	30.8	N/A
Shell Bottom	TP16	144"	28.6	30.9	N/A
Shell Bottom	TP17	144"	28.6	31.0	N/A
Shell Bottom	TP18	144"	28.6	30.8	N/A
Shell Bottom	TP19	144"	28.6	30.4	N/A
Shell Bottom	TP20	144"	28.6	30.3	N/A
Shell Bottom	TP21	144"	28.6	30.6	N/A
Shell Bottom	TP22	144"	28.6	30.9	N/A
Shell Bottom	TP23	144"	28.6	31.3	N/A
Shell Bottom	TP24	144"	28.6	30.9	N/A
Shell Bottom	TP25	144"	28.6	30.8	N/A
Shell Bottom	TP26	144"	28.6	30.4	N/A
Shell Bottom	TP27	144"	28.6	30.3	N/A
Shell Bottom	TP28	144"	28.6	30.3	N/A
Shell Bottom	TP28	144"	28.6	30.4	N/A
Shell Bottom	TP29	144"	28.6	30.6	N/A
Shell Bottom	TP30	144"	28.6	30.6	N/A
Shell Bottom	TP32	144"	28.6	30.9	N/A
Shell Bottom	TP33	144"	28.6	30.4	N/A
Shell Bottom	TP34	144"	28.6	30.6	N/A
Shell Bottom	TP35	144"	28.6	30.7	N/A
Shell Bottom	TP36	144"	28.6	30.9	N/A

End of Report



	U	Itrasoı	nic Inspect	ion S	ur	vey for Vessel In	spectio	n	
Location:		Point T	upper		EM&I J Report No.:		PT-D2100C-090511-JL-UT		
Client Name:		Exxon	Mobil Sable			Client Ref No.:		PT-1157	3614-001-D2100C
Client Rep.:		Dale G	roves			Inspector Name:		John Lee	Э
WO No.:		115736	11573614			Inspection Date:		March 1	1, 2009
SPO No.:		4501869140				Inspection Time:		Various	
Workscope No.:		PT-2008-VESSEL-EXT-03				System:		Propane	
Previous Report No. NA					EM&I J Job No:		EMJ013	2.33	
Ref. Drawing No.:		LA-B23	3-F-22-8051-0	)1-Z3, 9	98-0	CA-399735-1B-5, 98-	-CA-39973	35-4B-0	
Technician Certific	cations:	PCN U	T 2			Certification Expir	y Date:	May 21, 2012	
Inspection Code:		NA				Inspection Procedure:		EM&I	
Item Inspected:		D-2100	)C			Material (Incl. Vol.)	):	C/S	
Surface Condition	:	As coa	ted			Surface Temp:		Ambient	
Instrument	Туре	: Epoch	LTC	Equip	me	ent S/N: 090108103   Cal Due Date: March 1			arch 11, 2010
Instrument Setting	gs Refe	rence L	e Level: 80fsh Gain: 6					Settings: NA	
Search Unit Cable	s Type			Length				er Value:	
Calibration Block:		Step wedge 2.5-12.5mm		C	Calibration Block S/N:		09-1652		
Simulation Block:		NA			Č	Couplant:		Ultragel II	
Computerized Pro	gram:	NA							
Transducer Mfg:	Type:		Model No.:			Angle:	Frequen	cy:	Size:
Panametrics	Panametrics dual element D790SM - 6252		25220		0	5MHz		10mm	

Inspection Summary							
Restricted Access?	Yes	<b>⊡</b> No	Comments: Rope Access Required				

#### **Comments:**

UT spot readings were taken and the readings were recorded. See below and Attachment 3 for locations and readings. All readings are in millimeters.

Readings on North cap where taken facing South and South cap readings were taken facing North.



## **Inspection Summary**

			Nominal Wall	Minimum Wall	Average Wall
Item Identification	Test Point	Diameter (inches)	Thickness (mm)	Thickness (mm)	Thickness (mm)
North Cap	12 O'clock	End	28.2	32.0	, ,
North Cap	3 O'clock	End	28.2	31.7	
North Cap	6 O'clock	End	28.2	32.1	
North Cap	9 O'clock	End	28.2	31.2	
North Cap	Centre	End	28.2	32.1	
South Cap	12 O'clock	End	28.2	32.7	
South Cap	3 O'clock	End	28.2	32.1	
South Cap	6 O'clock	End	28.2	31.0	
South Cap	9 O'clock	End	28.2	32.7	
South Cap	Centre	End	28.2	31.6	
-					
Panel 1	West	144"	28.6	29.9	
Panel 1	Centre	144"	28.6	30.0	
Panel 1	East	144"	28.6	30.1	
Panel 2	West	144"	28.6	29.6	
Panel 2	Centre	144"	28.6	30.4	
Panel 2	East	144"	28.6	29.7	
Panel 3	West	144"	28.6	29.4	
Panel 3	Centre	144"	28.6	30.1	
Panel 3	East	144"	28.6	30.0	
Panel 4	West	144"	28.6	30.0	
Panel 4	Centre	144"	28.6	30.1	
Panel 4	East	144"	28.6	29.8	
Panel 5	West	144"	28.6	29.8	
Panel 5	Centre	144"	28.6	30.9	
Panel 5	East	144"	28.6	29.9	
Panel 6	West	144"	28.6	30.2	
Panel 6	Centre	144"	28.6	30.1	
Panel 6	East	144"	28.6	30.1	
Panel 7	West	144"	28.6	29.3	
Panel 7	Centre	144"	28.6	29.8	
Panel 7	East	144"	28.6	29.2	
Panel 8	West	144"	28.6	30.1	
Panel 8	Centre	144"	28.6	30.1	
Panel 8	East	144"	28.6	29.7	



# **Inspection Summary**

Item Identification	Test Point	Diameter (inches)	Nominal Wall Thickness (mm)	Minimum Wall Thickness (mm)	Average Wall Thickness (mm)
Panel 9	West	144"	28.6	29.7	
Panel 9	Centre	144"	28.6	30.2	
Panel 9	East	144"	28.6	30.1	
Panel 10	West	144"	28.6	29.7	
Panel 10	Centre	144"	28.6	29.8	
Panel 10	East	144"	28.6	29.7	
Panel 11	West	144"	28.6	30.1	
Panel 11	Centre	144"	28.6	30.1	
Panel 11	East	144"	28.6	30.3	
Panel 12	West	144"	28.6	29.9	
Panel 12	Centre	144"	28.6	29.9	
Panel 12	East	144"	28.6	30.0	

End of Report

Three UT readings were taken on each plate. One on the East, one top Center, and one on the West side. The areas are numbered and readings were recorded on the UT report. Only the lowest readings were reported.

