

Pressure Vessel Survey									
Location:	Point Tupper	.: PT-D2100D-090319-BR-R1							
Client Name:		Client Ref No.:			PT-11573615-001-D2100D				
Client Rep.:		Inspector Name:			Barry Ritchie				
WO No.:		Inspection Date:			March 19, 2009				
SPO No.:		System:			Propar				
Workscope No.:	PT-2008-VESSEL-EXT-03	EM&I J Job No:		EMJ0132.33					
Tag No.:	D-2100D	Equipment Descr	iption:		Propar	ne Sto	Storage Vessel D-2100D		
Date of Last Inspection:		Previous Records			NA				
Drawing No.:	LA-B23-F-22-8052-01-Z4, 98	30047-4-2, 980047-2	2-4, 98	-CA-C	399735	5-4B-0			
	Inspec	ction Summary							
	Item				dition		Comments		
External Ladders, Access a			Good	Fair	Poor	NA	1 1 0 1 0 0 5		
	ders, stairways, platforms and he vessel for signs of corrosion,		\boxtimes				As per report 2100E		
If applicable, check vessel deflection, and/or corrosion.	supports for signs of deterioration	on, settlement,	\square				See Photos #1-6		
	gs for signs of deterioration, rusts ondment.	s spots, cracks,				\boxtimes			
4. a) For horizontally mounted	d vessels, check for signs of trap		\square						
b) For vertically mounted v condensation, resulting in cor	essels on skirt support or suppor rosion on the bottom cap/ inside upport legs to the bottom cap.	t legs, check for				\boxtimes			
5. Check the grounding connection is correctly installed, with cable connections tight and ground wires in good condition.							See Photos #7,8,9,10		
6. Check all bolted connections for any signs of corrosion or mechanical damage.									
7. If applicable, check the ves free.	sel sliding foot free to move and	hold-down bolts are				\square			
Vessel External Surfaces			Good	Fair	Poor	NA			
 Check permanent identifyi required information. 	ng tags on vessel are legible and	d present the	\square				See Photo #11		
2. If applicable, check that all bolts/studs extend fully through their nuts, having a protrusion beyond the nut of not less than one thread; flange bolts have bolt heads all on the side of the joint.									
	connections are in full contact wi any signs of rust, corrosion or m		\square						
 If applicable, check insulati breakage. 	on support bands and clips for si	igns of corrosion or				\boxtimes			
5. Check all welded seams ar corrosion, cracking, pitting or	nd connections for any signs of d other sign of failure. Specify.	eterioration,	\square						
6) If applicable, check insulation type, condition for any insulation damage and ingress of water. Record insulation type.						\boxtimes			
7. Carry out visual inspection of the exterior surface of the vessel, including coatings for any signs of leaks, cracks, deformation, distortion, pitting, corrosion or other forms of deterioration. If so, specify type, location and extent.							See Photos #18-23, 26, 29, 30 , 31, 34, 35, 36		
8. If applicable, check weep holes in reinforcement plates are not plugged.				Fair					
External Piping / Instrument Attachments					Poor	NA	See Photo #12		
1. If applicable, check vessel trim, such as gauges, sight glasses, valves and other appurtenances, show signs of deterioration, or missing components, etc.									
number of PSV and calibratio		-	\square				See Photo #28		
	d other connections, including the istortion or cracks, wall loss, leak and location.			\boxtimes			See Photo #12-17, 24, 25, 27		



Inspection Summary								
Item	Comments							
Vessel Internal Surfaces	Good	Fair	Poor	NA	External Only			
1. Check for signs of corrosion, erosion, cracks, blisters, pitting, distortion, or other forms of deterioration on the internal vessel surfaces. If any, specify type, location and extent.				\boxtimes				
2. Check all welded joints for any signs of deterioration, corrosion, cracking, pitting or other sign of failure. Specify.				\boxtimes				
3. Check all man-ways, nozzles and connections for distortion, cracks, corrosion, wall loss and other type of defects or failures. If any defects are noted, specify type, extent and location.				\boxtimes				
4. If applicable, compare the results of performed wall thickness survey with previous reports for areas of wall thickness loss. Identify areas on inspection report.				\boxtimes				
5. Where applicable, check vessel internal cladding for signs of bulging, buckling, cracks, holes, etc. If any, specify type, location and extent.				\boxtimes				
6. Where applicable, check the vessel internal coating for signs of deterioration, such as: rust spots, blisters, coating disbandment, etc. If any, specify type, location and extent.				\boxtimes				
7. If possible, check gasket seals on all flanges for signs of corrosion and/or mechanical damage.				\boxtimes				
Internal Equipment/Piping /Supports	Good	Fair	Poor	NA				
 Where applicable, check supports for vessel's internal equipment and components for signs of corrosion, distortion and deterioration. 				\boxtimes				
2. If applicable, check vessel's internals for signs of corrosion, distortion and deterioration, missing components etc.				\boxtimes				
3. If applicable, check if bolted connections are in full contact with connected elements and connections are free from rust or other deleterious material that may prohibit full contact.				\square				

Detail of Findings

Instructions: With the aid of Drawing(s), Sketch(es) and Photo(s) describe findings

UT thickness readings were taken on areas where coating breakdown was noted. No areas of concern

ID Tag:

Certified By: RNG Pro-Tech Inc MAWP: 210/-11 PSI @ 149F MDMT: -17F @ 250/-11 PSI Serial No.: 98-9 Year Built: 1999 CRN: 8124.8

MAWP: 1724/-76 KPA @ 65C MDMT: -27C @ 1724/-76 KPA Year Built: 1999 CRN: 8124.8

PSV Tag:

L&S Job: 09-16828-19 Date: March 4, 2009 Set Pressure: 1723 KPA Capacity: 18649 SCFM Model: JPVM 15A



Detail of Findings Instructions: With the aid of Drawing(s), Sketch(es) and Photo(s) describe findings Photo 2 - South face of North vessel support, showing Photo 1 - North face of North vessel support, paint corrosion running along lower flange conection to coating in good condtion, photo taken facing South concrete support, photo taken facing South Photo 3 - South face of North vessel support , showing Photo 4 – South face of South vessel support showing corrosion running along lower flange conection to coating breakdown on upper flange, photo taken facing concrete support, photo taken facing South North



Detail of Findings Instructions: With the aid of Drawing(s), Sketch(es) and Photo(s) describe findings Photo 5 - North face of South vessel support, coating Photo 6- North face of South vessel support, coating breakdown on lower flange with damage to top Southbreakdown on lower flange with damage to top South-East vessel concrete support, taken facing West East vessel concrete support, taken facing West LARE LINE Photo 7 - Earth strap connections to be in good Photo 8 - Earth strap connections to be in good condition condition



Detail of Findings











Detail of Findings









Detail of Findings






Detail of Findings





Detail of Findings





List of Attachments

Attachment 1: PT-D2100D-090514-JL-UT (Page 1 to 4) Attachment 2: UT Diagram

End of Report



	U	Itraso	nic Inspect	tion S	ur	vey for Vessel In	spectio	n		
Location:		Point Tupper				EM&I J Report No.	:	PT-D210	00D-090514-JL-UT	
Client Name:		Exxon Mobil Sable				Client Ref No.:		PT-1157	'3615-001-D2100D	
Client Rep.:		Dale G	roves			Inspector Name:		John Le	9	
WO No.:		115736	615			Inspection Date:		March 1	4, 2009	
SPO No.:		450186	69140			Inspection Time:		Various		
Workscope No.:		PT-200	8-VESSEL-E	XT-03		System:		Propane)	
Previous Report N	lo.	NA				EM&I J Job No:		EMJ013	2.33	
Ref. Drawing No.:		LA-B2	3-F-22-8052-0)1-Z4, 9	980	047-4-2, 980047-2-4	, 98-CA-3	99735-4B	-0	
Technician Certifi	cations:	PCN U	Τ2			Certification Expir	y Date:	May 21,	2012	
Inspection Code:		NA			EM&I					
Item Inspected:		D2100	D			Material (Incl. Vol.)	Material (Incl. Vol.):		C/S	
Surface Condition	1:	As coa	ted			Surface Temp:		Ambient		
Instrument	Туре	: Epoch	LTC	Equip	ome	ent S/N: 090108103	03 Cal Due Date: March 11, 2010			
Instrument Setting	gs Refe	rence L	evel: 80fsh	Gain:	60	db	Reject Settings: NA			
Search Unit Cable	s Type	:		Lengt	th:	5'	Transfe	r Value:		
Calibration Block:		Step w	edge 2.5-12.5	ōmm	С	alibration Block S/N	:	09-1652		
Simulation Block:		NA			С	ouplant:		Ultragel II		
Computerized Pro	ogram:	NA								
Transducer Mfg:	Type:	Model No.:			Angle:	Frequency:		Size:		
Panametrics	dual elen	ment D790SM - 625220			0 5MHz			10mm		

Inspection Summary						
Restricted Access?	🖸 Yes	🖸 No	Comments: Rope Access Required			

Comments:

UT spot readings were taken and the readings were recorded. See below and Attachment 3 for locations and readings. All readings are in millimeters.

Readings on North cap were taken facing South and South cap readings were taken facing North.



	Inspection Summary							
Item Identification	Test Point	Diameter (inches)	Nominal Wall Thickness (mm)	Minimum Wall Thickness (mm)	Average Wall Thickness (mm)			
North Head	12 O'clock	End	28.2	31.7				
North Head	3 O'clock	End	28.2	31.6				
North Head	6 O'clock	End	28.2	32.1				
North Head	9 O'clock	End	28.2	31.6				
North Head	Centre	End	28.2	30.8				
South Head	12 O'clock	End	28.2	31.8				
South Head	3 O'clock	End	28.2	32.2				
South Head	6 O'clock	End	28.2	31.5				
South Head	9 O'clock	End	28.2	32.0				
South Head	Centre	End	28.2	31.4				
Panel 1	West	144"	28.6	29.9				
Panel 1	Centre	144"	28.6	29.9				
Panel 1	East	144"	28.6	29.5				
Panel 2	West	144"	28.6	29.5				
Panel 2	Centre	144"	28.6	29.2				
Panel 2	East	144"	28.6	29.4				
Panel 3	West	144"	28.6	30.3				
Panel 3	Centre	144"	28.6	30.1				
Panel 3	East	144"	28.6	30.1				
Panel 4	West	144"	28.6	30.3				
Panel 4	Centre	144"	28.6	30.2				
Panel 4	East	144"	28.6	30.4				
Panel 5	West	144"	28.6	30.0				
Panel 5	Centre	144"	28.6	29.7				
Panel 5	East	144"	28.6	29.6				
Panel 6	West	144"	28.6	29.7				
Panel 6	Centre	144"	28.6	29.4				
Panel 6	East	144"	28.6	29.8				
Panel 7	West	144"	28.6	29.9				
Panel 7	Centre	144"	28.6	30.4				
Panel 7	East	144"	28.6	29.6				
Panel 8	West	144"	28.6	29.8				
Panel 8	Centre	144"	28.6	30.1				
Panel 8	East	144"	28.6	29.6				




	Ins	spection Sun	nmary		
Item Identification	Test Point	Diameter (inches)	Nominal Wall Thickness (mm)	Minimum Wall Thickness (mm)	Average Wall Thickness (mm)
Panel 9	West	144"	28.6	29.6	
Panel 9	Centre	144"	28.6	29.8	
Panel 9	East	144"	28.6	29.3	
Panel 10	West	144"	28.6	29.8	
Panel 10	Centre	144"	28.6	29.7	
Panel 10	East	144"	28.6	29.7	
Panel 11	West	144"	28.6	30.2	
Panel 11	Centre	144"	28.6	29.8	
Panel 11	East	144"	28.6	29.6	
Panel 12	West	144"	28.6	30.0	
Panel 12	Centre	144"	28.6	30.3	
Panel 12	East	144"	28.6	29.8	
Nozzle 1	North	4"	33.1	33.4	
Nozzle 1	South	4"	33.1	33.0	
Nozzle 1	East	4"	33.1	32.9	
Nozzle 1	West	4"	33.1	33.1	
Nozzle 2	North	10"	82.6	82.2	
Nozzle 2	South	10"	82.6	81.0	
Nozzle 2	East	10"	82.6	82.0	
Nozzle 2	West	10"	82.6	82.0	
Nozzle 3A	North	3"	31.5	31.4	
Nozzle 3A	South	3"	31.5	31.2	
Nozzle 3A	East	3"	31.5	31.5	
Nozzle 3A	West	3"	31.5	31.5	
Nozzle 3B	North	3"	31.5	31.1	
Nozzle 3B	South	3"	31.5	31.0	
Nozzle 3B	East	3"	31.5	31.3	
Nozzle 3B	West	3"	31.5	31.0	
Nozzle 4A	North	2"	16.6	16.7	
Nozzle 4A	South	2"	16.6	16.8	
Nozzle 4A	East	2"	16.6	16.9	
Nozzle 4A	West	2"	16.6	16.8	
Nozzle 4B	North	2"	16.6	16.5	
Nozzle 4B	South	2"	16.6	16.7	
Nozzle 4B	East	2"	16.6	17.0	
Nozzle 4B	West	2"	16.6	16.7	



	In	spection Sur	nmary		
Item Identification	Test Point	Diameter (inches)	Nominal Wall Thickness (mm)	Minimum Wall Thickness (mm)	Average Wall Thickness (mm)
Nozzle 5	North	4"	33.1	32.8	
Nozzle 5	South	4"	33.1	33.0	
Nozzle 5	East	4"	33.1	32.8	
Nozzle 5	West	4"	33.1	32.4	
Nozzle 6	Тор	2"	25.4	25.0	
Nozzle 6	Bottom	2"	25.4	24.8	
Nozzle 6	East	2"	25.4	24.9	
Nozzle 6	West	2"	25.4	25.1	
Nozzle 7	North	4"	33.1	34.1	
Nozzle 7	South	4"	33.1	34.4	
Nozzle 7	East	4"	33.1	34.4	
Nozzle 7	West	4"	33.1	33.9	
Nozzle 8	North	6"	63.5	66.3	
Nozzle 8	South	6"	63.5	66.4	
Nozzle 8	East	6"	63.5	66.3	
Nozzle 8	West	6"	63.5	66.4	
Nozzle 9	North	2"	16.6	17.0	
Nozzle 9	South	2"	16.6	17.0	
Nozzle 9	East	2"	16.6	16.8	
Nozzle 9	West	2"	16.6	17.2	
Nozzle 10	North	3"	31.5	30.9	
Nozzle 10	South	3"	31.5	31.1	
Nozzle 10	East	3"	31.5	30.9	
Nozzle 10	West	3"	31.5	30.7	
Nozzle 11	North	2"	16.6	17.4	
Nozzle 11	South	2"	16.6	18.0	
Nozzle 11	East	2"	16.6	18.3	
Nozzle 11	West	2"	16.6	17.9	
M1	North	24"	101.6	110	
M1	South	24"	101.6	110	
M1	East	24"	101.6	110	
M1	West	24"	101.6	110	

End of Report

Three UT readings were taken on each plate. One on the East, one top Center, and one on the West side. The areas are numbered and readings were recorded on the UT report. Only the lowest readings were reported.



PT-11573615-001-D2100D