

	Pressui	re Vessel Survey							
Location:	Point Tupper	EM&I J Report N	o.:	o.: PT-D2100E-090317-BR-R1					
Client Name:		Client Ref No.:			16-001-D2100E				
Client Rep.:		Inspector Name:			Barry	Barry Ritchie			
WO No.:		Inspection Date:			March	2009			
SPO No.:		System:			Propa	ane			
Workscope No.:			EMJC	132.3	3				
Workscope No.:PT-2008-VESSEL-EXT-03EM&I J Job No:Tag No.:D-2100EEquipment Desc					Propa	ane St	orage Vessel D-2100E		
Date of Last Inspection: NA Previous Record					NA				
Drawing No.:	LA-B23-F-22-8052-01-Z4, 98	0047-4-2, 980047-2	2-4, 98	S-CA-3	99735	5-4B-0			
	Inspec	tion Summary							
	Item			Cond	dition		Comments		
External Ladders, Access a	and Support Structure		Good	Fair	Poor	NA			
	ders, stairways, platforms and								
	the vessel for signs of corrosion, i	missing components,	\boxtimes						
or deterioration.									
deflection, and/or corrosion.	I supports for signs of deterioration	on, settlement,		\boxtimes			Areas of concern see		
	gs for signs of deterioration, rusts	enote cracke					Photos #8, 9 & 10		
blistering, and/or coating disk		s spots, cracks,	\boxtimes	Ш	Ш				
4. a) For horizontally mounted vessels, check for signs of trapped moisture,							See Photo #4		
resulting in corrosion betwee	n cradle support and vessel shell.	•		\boxtimes					
	ressels on skirt support or support								
	rrosion on the bottom cap/ inside	skirt support surface							
or area of attachment of the s	support legs to the bottom cap.		1						



Inspection Summary								
Item	Comments							
Vessel Internal Surfaces	Good	Fair	Poor	NA	External Only			
1. Check for signs of corrosion, erosion, cracks, blisters, pitting, distortion, or other forms of deterioration on the internal vessel surfaces. If any, specify type, location and extent.				\boxtimes				
2. Check all welded joints for any signs of deterioration, corrosion, cracking, pitting or other sign of failure. Specify.				\boxtimes				
3. Check all man-ways, nozzles and connections for distortion, cracks, corrosion, wall loss and other type of defects or failures. If any defects are noted, specify type, extent and location.				\boxtimes				
4. If applicable, compare the results of performed wall thickness survey with previous reports for areas of wall thickness loss. Identify areas on inspection report.				\boxtimes				
5. Where applicable, check vessel internal cladding for signs of bulging, buckling, cracks, holes, etc. If any, specify type, location and extent.				\boxtimes				
6. Where applicable, check the vessel internal coating for signs of deterioration, such as: rust spots, blisters, coating disbandment, etc. If any, specify type, location and extent.				\boxtimes				
7. If possible, check gasket seals on all flanges for signs of corrosion and/or mechanical damage.				\boxtimes				
Internal Equipment/Piping /Supports	Good	Fair	Poor	NA				
1. Where applicable, check supports for vessel's internal equipment and components for signs of corrosion, distortion and deterioration.				\boxtimes				
2. If applicable, check vessel's internals for signs of corrosion, distortion and deterioration, missing components etc.				\boxtimes				
3. If applicable, check if bolted connections are in full contact with connected elements and connections are free from rust or other deleterious material that may prohibit full contact.				\boxtimes				
Detail of Findings Instructions: With the aid of Drawing(s), Sketch(es) and	Photo	(s) de	scribe	findin	ne			

ID Tag:

Certified By: RNG Pro-Tech Inc MAWP: 210/-11 PSI @ 149F MDMT: -17F @ 250/-11 PSI

Serial No.: 98-10 Year Built: 1999 **CRN:** 8124.8

MAWP: 1724/-76 KPA @ 65C MDMT: -27C @ 1724/-76 KPA

Year Built: 1999 **CRN:** 8124.8

PSV Tag:

L&S Job: 09-16828-5 Date: February 24, 2009 Set Pressure: 1723 KPA Capacity: 18656 SCFM Model: JPVM-15A

Detail of Findings





Photo 1 – North face on North vessel support coating breakdown on steel to concrete connection, also coating breakdown on weld connection to vessel

Photo 2 – South face on North vessel support coating breakdown on concrete connection, weld connections on vertical stifferners starting to break down





Photo 3 – South vessel support south face slight coating breakdown on cradle and vessel

Photo 4 – South vessel support South-East corner water damage to concrete

Detail of Findings





Photo 5 – North face of South vessel support slight coating breakdown on concrete connection and coating breakdown on craddle

Photo 6 – North face of South vessel support, taken facing East, paint coating peeling back





Photo 7 – Earthing strap on North vessel support

Photo 8 – Earthing strap Joint on North vessel support, also showing horizontal crack in concrete support

Detail of Findings





Photo 9 - Close-up of crack shown in Photo 8

Photo 10 – Horizontal crack running along the South face of concrete block of North vessel support



Photo 11 – Earthing strap connection on South vessel support



Photo 12 - Showing ID plate

Detail of Findings





Photo 13 - Showing ID plate

Photo 14 – General condtion of nozzle N6 studs and nuts CAT III








Photo 16 – Nozzle N2, slight coating coating breakdown on nozzle, studs and nuts CAT III

Detail of Findings





Photo 17 – Nozzle N5, 35% of nozzle area has coating loss, studs and nuts CAT III

Photo 18 – General condtion of manhole, coating has started to breakdown only on the East side








Photo 20 – Showing general condtion of east side shell. Taken facing North

Detail of Findings

Instructions: With the aid of Drawing(s), Sketch(es) and Photo(s) describe findings





Photo 21 – Showing general condtion of east side shell, taken facing North

Photo 22 – Showing general condtion of east side shell. Taken facing North, showing one isolated patch located in the mid bottom section on weld seam approx 100mm x 100mm





Photo 23 – Showing general condtion of east side shell, taken facing North

Photo 24 – North dome end, generally in good condtion

Detail of Findings





Photo 25 – General good condtion of West side shell only one patch of coating breakdown shown, photo taken facing South

Photo 26 – General good condtion of West side shell only one patch of coating breakdown shown, photo taken facing South








Photo 28 – General good condtion of West side shell only one patch of coating breakdown shown, photo taken facing South

Detail of Findings

Instructions: With the aid of Drawing(s), Sketch(es) and Photo(s) describe findings






Photo 29 – General view of vessel top, all in good condtion, photo taken facing North

Photo 30 – Nozzels located at South end top N3A, N4A, N8 & N1, showing general condtion all studs and nuts at this location are in good condtion, CAT III








Photo 32 – General view of nozzle N9 studs and nuts CAT III

Detail of Findings





Photo 33 – Typical condtion of deluge pipe supports located along vessel top

Photo 34 – Showing upper section of South-West side shell a few very small areas of coating breakdown





Photo 35 - PSV calibration tag

Photo 36 – Nozzle N7 PSV, coating breakdown around nozzle studs and nuts CAT III



Detail of Findings

Instructions: With the aid of Drawing(s), Sketch(es) and Photo(s) describe findings






Photo 37 – N7 coating loss

Photo 38 – Showing patch next to N7 largest area of coating breakdown found so far approx 200mm x 150mm light to moderate corrosion. The corrosion will be removed and a UT scan will be carried out and noted in the UT report

List of Attachments

Attachment 1: PT-D2100E-090514-JL-UT (Page 1 to 4)

Attachment 2: UT Diagram

End of Report



	U	Itrasoi	nic Inspect	ion S	ur	vey for Vessel In	spectio	n	
Location:		Point T			EM&I J Report No.	:	PT-D2100E-090514-JL-UT		
Client Name:		Exxon	Mobil Sable			Client Ref No.:		PT-1157	'3616-001-D2100E
Client Rep.:		Dale G	roves			Inspector Name:		John Lee	
WO No.:		115736	616			Inspection Date:		March 1	4, 2009
SPO No.:		450186	69140			Inspection Time:		Various	
Workscope No.:		PT-200	08-VESSEL-E	XT-03		System:		Propane	,
Previous Report N	lo.	NA				EM&I J Job No:		EMJ013	2.33
Ref. Drawing No.:		LA-B23	3-F-22-8052-0)1-Z4, 9	980	047-4-2, 980047-2-4	, 98-CA-3	99735-4B	-0
Technician Certific	cations:	PCN U	T 2			Certification Expir	y Date:	May 21, 2012	
Inspection Code:		NA			Inspection Procedure:			EM&I	
Item Inspected:		D2100	E		Material (Incl. Vol.):			C/S	
Surface Condition	:	As coa	ted			Surface Temp:		Ambient	
Instrument	Туре	: Epoch	LTC	Equip	me	nent S/N: 090108103 Cal Due Date: March 11, 201			arch 11, 2010
Instrument Setting	js Refe	rence L	evel: 80fsh	Gain:	60	Odb Reject Settings: NA			NA
Search Unit Cables	s Type	:		Lengt	h:	5'	Transfe	r Value:	
Calibration Block:		Step w	edge 2.5-12.5	ōmm	C	alibration Block S/N	l :	09-1652	
Simulation Block:		NA		Couplant:			Ultragel II		
Computerized Pro	gram:	NA							
Transducer Mfg:	Type:	Model No.:				Angle: Frequen		cy:	Size:
Panametrics	dual elen	ment D790SM - 62		25220	0		5MHz		10mm
					_				

Inspection Summary						
Restricted Access?	Yes	☑ No	Comments: Rope Access Required			

Comments:

UT spot readings were taken and the readings were recorded. See below and Attachment 3 for locations and readings. All readings are in millimeters.

Readings on North cap were taken facing South and South cap readings were taken facing North.

UT reading on Nozzle N2 exceeds 2.2mm corrosion allowance.



Inspection Summary

Item Identification	Test Point	Diameter (inches)	Nominal Wall Thickness (mm)	Minimum Wall Thickness (mm)	Average Wall Thickness (mm)
North Head	12 O'clock	End	28.2	32.8	
North Head	3 O'clock	End	28.2	32.4	
North Head	6 O'clock	End	28.2	32.5	
North Head	9 O'clock	End	28.2	32.6	
North Head	Centre	End	28.2	31.6	
South Head	12 O'clock	End	28.2	32.3	
South Head	3 O'clock	End	28.2	32.0	
South Head	6 O'clock	End	28.2	32.3	
South Head	9 O'clock	End	28.2	32.2	
South Head	Centre	End	28.2	32.1	
Panel 1	West	144"	28.6	29.9	
Panel 1	Centre	144"	28.6	29.9	
Panel 1	East	144"	28.6	29.5	
Panel 2	West	144"	28.6	29.9	
Panel 2	Centre	144"	28.6	30.0	
Panel 2	East	144"	28.6	29.7	
Panel 3	West	144"	28.6	29.8	
Panel 3	Centre	144"	28.6	29.9	
Panel 3	East	144"	28.6	30.0	
Panel 4	West	144"	28.6	29.8	
Panel 4	Centre	144"	28.6	30.3	
Panel 4	East	144"	28.6	29.5	
Panel 5	West	144"	28.6	30.2	
Panel 5	Centre	144"	28.6	29.8	
Panel 5	East	144"	28.6	30.3	
Panel 6	West	144"	28.6	29.1	
Panel 6	Centre	144"	28.6	29.0	
Panel 6	East	144"	28.6	29.3	
Panel 7	West	144"	28.6	29.5	
Panel 7	Centre	144"	28.6	29.5	
Panel 7	East	144"	28.6	29.5	
Panel 8	West	144"	28.6	29.8	
Panel 8	Centre	144"	28.6	29.5	
Panel 8	East	144"	28.6	29.6	



Inspection Summary

Item Identification	Test Point	Diameter (inches)	Nominal Wall Thickness (mm)	Minimum Wall Thickness (mm)	Average Wall Thickness (mm)
Panel 9	West	144"	28.6	29.3	, ,
Panel 9	Centre	144"	28.6	29.3	
Panel 9	East	144"	28.6	29.3	
Panel 10	West	144"	28.6	29.6	
Panel 10	Centre	144"	28.6	30.0	
Panel 10	East	144"	28.6	29.8	
Panel 11	West	144"	28.6	30.1	
Panel 11	Centre	144"	28.6	29.7	
Panel 11	East	144"	28.6	30.0	
Panel 12	West	144"	28.6	29.9	
Panel 12	Centre	144"	28.6	30.1	
Panel 12	East	144"	28.6	29.8	
Nozzle 1	North	4"	33.1	32.8	
Nozzle 1	South	4"	33.1	33.0	
Nozzle 1	East	4"	33.1	33.1	
Nozzle 1	West	4"	33.1	32.9	
Nozzle 2	North	10"	82.6	81.1	
Nozzle 2	South	10"	82.6	80.9	
Nozzle 2	East	10"	82.6	80.4	
Nozzle 2	West	10"	82.6	81.0	
Nozzle 3A	North	3"	31.5	31.3	
Nozzle 3A	South	3"	31.5	31.0	
Nozzle 3A	East	3"	31.5	31.7	
Nozzle 3A	West	3"	31.5	31.4	
Nozzle 3B	North	3"	31.5	31.5	
Nozzle 3B	South	3"	31.5	31.4	
Nozzle 3B	East	3"	31.5	31.4	
Nozzle 3B	West	3"	31.5	31.6	
Nozzle 4A	North	2"	16.6	16.9	
Nozzle 4A	South	2"	16.6	16.7	
Nozzle 4A	East	2"	16.6	16.6	
Nozzle 4A	West	2"	16.6	17.1	
Nozzle 4B	North	2"	16.6	16.9	
Nozzle 4B	South	2"	16.6	16.6	
Nozzle 4B	East	2"	16.6	17.1	
Nozzle 4B	West	2"	16.6	17.0	



Inspection Summary

Item Identification	Test Point	Diameter (inches)	Nominal Wall Thickness (mm)	Minimum Wall Thickness (mm)	Average Wal Thickness (mm)
Nozzle 5	North	4"	33.1	32.9	` '
Nozzle 5	South	4"	33.1	32.9	
Nozzle 5	East	4"	33.1	32.9	
Nozzle 5	West	4"	33.1	32.9	
Nozzle 6	Тор	2"	25.4	24.7	
Nozzle 6	Bottom	2"	25.4	24.8	
Nozzle 6	East	2"	25.4	24.1	
Nozzle 6	West	2"	25.4	25.0	
Nozzle 7	North	4"	33.1	35.1	
Nozzle 7	South	4"	33.1	34.9	
Nozzle 7	East	4"	33.1	34.7	
Nozzle 7	West	4"	33.1	35.0	
Nozzle 8	North	6"	63.5	66.2	
Nozzle 8	South	6"	63.5	66.2	
Nozzle 8	East	6"	63.5	66.2	
Nozzle 8	West	6"	63.5	66.0	
Nozzle 9	North	2"	16.6	17.1	
Nozzle 9	South	2"	16.6	16.9	
Nozzle 9	East	2"	16.6	16.8	
Nozzle 9	West	2"	16.6	17.1	
Nozzle 10	North	3"	31.5	31.0	
Nozzle 10	South	3"	31.5	30.8	
Nozzle 10	East	3"	31.5	30.8	
Nozzle 10	West	3"	31.5	31.0	
Nozzle 11	North	2"	16.6	16.9	
Nozzle 11	South	2"	16.6	17.1	
Nozzle 11	East	2"	16.6	17.1	
Nozzle 11	West	2"	16.6	16.9	
M1	North	24"	101.6	110	
M1	South	24"	101.6	110	
M1	East	24"	101.6	110	
M1	West	24"	101.6	110	

End of Report

Three UT readings were taken on each plate. One on the East, one top Center, and one on the West side. The areas are numbered and readings were recorded on the UT report. Only the lowest readings were reported.

